

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 20/5/2026

It is certified that an inspection team headed by V.G. DAS

(Name of Officers with designation) from CHC Champakulam PHED

inspected the Fr. Thomas Porukara Central School

(Name & Address of the school) on 20/5/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 469/A/2026 dated 13/5/26

of Quality Control District Lab Kerala (PHED Lab) certified that the

Fr. Thomas Porukara Central School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 12-5-2027

Signature with Seal: [Signature]

Name: V.G. DAS


Designation: Jr. Health Inspector

Name & Address of the Office / Department: CHC

Champakulam

To

(Name & Address of the Institution)



V.G. DAS

Jr. HEALTH INSPECTOR Gr. I

C.H.C., CHAMPAKULAM

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
ALAPPUZHA

Telephone No. 0477-2990650, Email: aeqedlalpy@gmail.com
TC-14216



WATER ANALYSIS REPORT

ULR-TC1421626000000418F

Report No.469/A/2026

Report Date. 15/05/2026

Customer Name & Address FR THOMAS PORUKARA CENTRAL SCHOOL CHAMPAKULAM P. O ALAPPUZHA	Date of Receipt	: 12/05/2026
	Date of Sample Collection	: 12/05/2026
	Date of Sample Received	: 12/05/2026
	Time of sampling	: Not Applicable
	Sampling done by	: Customer
	Sample Code	: 2026/QCDL/ALPY 1578
	Source of Sample	: Drinking Water (R.O Water)
	Sampling Method	: Not Applicable
	Nature of Container	: Polypropylene
	Sample Quantity	: 2 L
Test performing dates		: From 12/05/2026 to 13/05/2026

Sl. No	Characteristics	Unit	Desirable limits as per IS 10500:2012	Permissible limit in the absence of alternative source IS10500:2012	Test Method	Result
1	Colour	Pt-Co Unit	5	15	APHA 24 th edition 2120 B	< 5
2	Odour	-	-	Agreeable	IS 3025(part 5): 2018	Agreeable
3	Taste	-	-	Not Objectionable	IS 3025 (Part 8): 2023	Not Objectionable
4	Turbidity	(NTU)	1	5	IS 3025(part 10): 2023 Nephelometric Method	0.85
5	pH at 25°C	-	6.5-8.5	No Relaxation	IS 3025(part II): 2022 Potentiometric Method	7.71
6	Electrical Conductivity at 25°C	(micro mhos/cm)	-	-	IS 3025(part 14): 2013 (Reaffirmed 2023)	39
7	Total Dissolved Solids (TDS) at 180°C	(mg/litre)	500	2000	IS 3025(part 16): 2023 Gravimetric Method	28
8	Acidity	(mg/litre)	-	-	IS 3025(part 22): 2024 Indicator Method	4
9	Total Alkalinity (as CaCO ₃)	(mg/litre)	200	600	IS 3025(part 23): 2023 Indicator Method	19

Verified By:

Jula T
Technical Manager



Authorized by

Elizabeth John
Quality Manager

Sanitary Chemist
Quality Control District Lab
Kerala Water Authority
Alappuzha - 688001

NB: The result stated above related only to the sample(s) submitted for testing. The test Certificate shall not be produced except in full without the written approval of the Laboratory.
Sample will be retained only for 7 days after completion of analysis
Sampling is not done by the Lab
BDL-Below Detection Limit

Page 1-3

KWA/ALPY/A F4	Issue No. 01	Issue Date: 01.09.2021	Rev. No. 05	Rev. Date: 01/04/2026
---------------	--------------	------------------------	-------------	-----------------------



QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
ALAPPUZHA

Telephone No. 0477-2990650, Email: aeqcdlalpy@gmail.com



TC-14216

WATER ANALYSIS REPORT

ULR-TC1421626000000418F


Report No.469/A/2026	Report Date. 15/05/2026
----------------------	-------------------------

FR THOMAS PORUKARA CENTRAL SCHOOL CHAMPAKULAM P. O ALAPPUZHA	Customer Name & Address	Date of Receipt	: 12/05/2026
		Date of Sample Collection	: 12/05/2026
		Date of Sample Received	: 12/05/2026
		Time of sampling	: Not Applicable
		Sampling done by	: Customer
		Sample Code	: 2026/QCDL/ALPY 1578
		Source of Sample	: Drinking Water (R.O Water)
		Sampling Method	: Not Applicable
		Nature of Container	: Polypropylene
		Sample Quantity	: 2 L
		Test performing dates	: From 12/05/2026 to 13/05/2026

Sl. No	Characteristics	Unit	Desirable limits as per IS 10500:2012	Permissible limit in the absence of alternative source IS10500:2012	Test Method	Result
10	Total Hardness (as CaCO ₃)	(mg/litre)	200	600	IS 3025(part 21): 2009 (Reaffirmed 2023), EDTA Method	16
11	Calcium(as Ca)	(mg/litre)	75	200	IS 3025(part 40): 2024 EDTA Titrimetric Method	4.8
12	Magnesium (as Mg)	(mg/litre)	30	100	APHA 24 th Edition 3500 – Mg B Calculation Method	0.98
13	Chloride (as Cl)	(mg/litre)	250	1000	IS 3025(part 32): 2025 Argentometric Method	9.6
14	Nitrate (as NO ₃)	(mg/litre)	45	No Relaxation	APHA 24 th edition 4500 – NO ₃ B Ultraviolet Spectrophotometric Screening Method	2.18
15	Sulphate (as SO ₄)	(mg/litre)	200	400	IS 3025(part 24/Sec 1): 2022 Turbidity Method	1.62
16	Iron (as Fe)	(mg/litre)	1	No Relaxation	IS 3025(part 53): 2024 1,10 Phenanthroline Method	0.15
17	Fluoride (as F)	(mg/litre)	1	1.5	APHA 24 th edition 4500 – F – D SPADNS Method	0.11

Verified By:

Jula T
Technical Manager



Authorized by

Elizabeth John
Quality Manager

Sanitary Chemist
Quality Control District Lab
Kerala Water Authority
Alappuzha - 688001

NB: The result stated above related only to the sample(s) submitted for testing. The test Certificate shall not be produced except in full without the written approval of the Laboratory.
Sample will be retained only for 7 days after completion of analysis
Sampling is not done by the Lab
BDL-Below Detection Limit

Page 2-3

KWA/ALPY/A F4	Issue No. 01	Issue Date: 01.09.2021	Rev. No. 05	Rev. Date: 01/04/2026
---------------	--------------	------------------------	-------------	-----------------------

QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
ALAPPUZHA

Telephone No. 0477-2990650, Email: aeqcdlalpy@gmail.com



WATER ANALYSIS REPORT

Report No.469/A/2026

Report Date. 15/05/2026

Customer Name & Address FR THOMAS PORUKARA CENTRAL SCHOOL CHAMPAKULAM P. O ALAPPUZHA	Date of Receipt	: 12/05/2026
	Date of Sample Collection	: 12/05/2026
	Date of Sample Received	: 12/05/2026
	Time of sampling	: Not Applicable
	Sampling done by	: Customer
	Sample Code	: 2026/QCDL/ALPY 1578
	Source of Sample	: Drinking Water (R.O Water)
	Sampling Method	: Not Applicable
	Nature of Container	: Polypropylene
	Sample Quantity	: 2 L.
Test performing dates		: From 12/05/2026 to 13/05/2026

Sl. No	Characteristics	Unit	Desirable limits As per IS 10500:2012	Permissible limit in Absence of Alternative source IS 10500:2012	Test Method	Result
1	Residual Chlorine	(mg/litre)	0.2	0.2	IS 3025(Part 26)	Nil

Verified By:

Jula T
Technical Manager

Authorized by

Elizabeth John
Quality Manager

Sanitary Chemist
Quality Control District Lab
Kerala Water Authority
Alappuzha - 688001

Remarks :-

NB: The result stated above related only to the sample(s) submitted for testing. The test Certificate shall not be produced except in full without the written approval of the Laboratory.
Sample will be retained only for 7 days after completion of analysis
Sampling is not done by the Lab
BDL-Below Detection Limit

Page ! -1

End of the report

KWA/ALPY/A F4	Issue No. 01	Issue Date: 01.09.2021	Rev. No. 03	Rev. Date: 08/06/2024
---------------	--------------	------------------------	-------------	-----------------------



QUALITY CONTROL DISTRICT LAB

KERALA WATER AUTHORITY

ALAPPUZHA

Telephone No. 0477-2990650, Email: aeqcdlalpy@gmail.com



TC-14216

WATER ANALYSIS REPORT

ULR-TC1421626000000418F

Report No.469/A/2026

Report Date. 15/05/2026

Customer Name & Address FR THOMAS PORUKARA CENTRAL SCHOOL CHAMPAKULAM P. O ALAPPUZHA	Date of Receipt	: 12/05/2026
	Date of Sample Collection	: 12/05/2026
	Date of Sample Received	: 12/05/2026
	Time of sampling	: Not Applicable
	Sampling done by	: Customer
	Sample Code	: 2026/QCDL/ALPY 1578
	Source of Sample	: Drinking Water (R.O Water)
	Sampling Method	: Not Applicable
	Nature of Container	: Glass
	Sample Quantity	: 250 ml
Test performing dates		: From 12/05/2026 to 13/05/2026

No	Parameters	Acceptable limits as per – IS 10500 - 2012	Test Method	Result
1	Total Coliforms/100ml	Shall not be detected/100 ml	IS15185:2016 (Reaffirmed 2021)	Absent
2	E. coli/100ml	Shall not be detected/100 ml	IS15185:2016 (Reaffirmed 2021)	Absent

NB:-The results stated above related only to the sample(s) submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.



Verified & Authorized by

[Signature]

Dr. Tijith K George
Microbiologist

Bacteriologist
Quality Control District Lab
Kerala Water Authority
Alappuzha - 688001



KWA/ALPY/A F4	Issue No. 01	Issue Date: 01.09.2021	Rev. No. 02	Rev. Date: 21/02/2026
---------------	--------------	------------------------	-------------	-----------------------